

SUBMITTAL NO.	
PROJECT REF	

M	10	n	F		N	ш	I٨	Λ	R	F	D	
IV	ıv	v	ᆮ	ᆫ	IN	u	ı۱۷	//	₽	ᆮ	К	ā

SINGLE-PROCESS CONTROL PANEL W/ TOUCH PANEL INTERFACE

SCP - TP - ____ - ____

CATALOG SELECTION:

SCP-TP-XX-XXXXXX

FRONT DOOR-CD - CLEAR DOOR

OD - OPAQUE DOOR

SUPPLY VOLTAGE

120VAC -120VAC, 60 Hz (Main Supply, Solenoid Supply) 240VAC - 240VAC, 50 Hz (Main Supply, Solenoid Supply)

024VDC - 24VDC (Main Supply, Solenoid Supply)

CONTROL SELECTION CONFIGURATION:

**NOTE: INFORMATION BELOW WILL BE USED FOR FACTORY TO PRESET CONTROL PANEL CONFIGURATION TO ASSIST USER. MISSING INFORMATION WILL NEED TO BE CONFIGURED BY USER AT TIME OF COMMISSIONING

APPLICATION (CHOOSE ONE OF THE FOLLOWING):

\Box 1	MODULATING	SINGLE	PROCESS	CONTROL
	111000000000000000000000000000000000000	00	11100000	CONTINCE

- ☐ VALVE POSITION ☐ PRESSURE REDUCING
- ☐ FLOW ☐ PRESSURE SUSTAINING
- ☐ MODULATING LEVEL
- ☐ 2 ON/OFF CONTROL
 - ☐ ON/OFF LEVEL ☐ OTHER:_
- ☐ 3 MOTORIZED 4-20mA ACTUATOR CONTROL
 - ☐ 420DC
- ☐ OTHER:

PROCESS VARIABLE CONFIGURATION

TRANSMITTER RANGE:

ALARM/RELAY OUTPUT (CHOOSE TWO OF THE FOLLOWING):


- ☐ 1 SENSOR BREAK
- ☐ 5 MODBUS TOGGLE
- □ 2 MANUAL MODE
- ☐ 6 STRAINER FLUSH
- □ 3 LOCAL/REMOTE
- ☐ 4 POSITIONING ALARM

MODBUS COMMUNICATION (CHOOSE ONE OF THE FOLLOWING):

- ☐ 1 SERIAL
- ☐ ENABLE
- ☐ 2 ETHERNET
- ☐ ENABLE

FORM

FILLED OUT OR EDITED BY:	
	_





SCREEN AND KEYPAD INSTALLED ON AN INTERNAL DOOR

POLYCARBONATE

ENCLOSURE STANDARD SPECIFICATION:

MATERIAL:

ENVIRONMENTAL RATING: NEMA TYPE 4,4X,12,13

IEC 60529, IP66, IP67 DIMENSIONS: 11.81"(300mm) x 11.81"(300mm)

x 7.49" (190mm)

ADDITIONAL NOTES:

-		

This quotation/submittal is for panels(s) described above and reflects our understanding of functions required. We assume no responsibility for meeting all stated or implied requirements beyond functions listed above. If above does not adequately describe functions/operation of above products, please ask for a more comprehensive description and mention areas where above description is deficient.